Specification

#	Designation	Name	Q-ty	Unit weight, kg	Note
1		Battery system	18		
2		PCS&MV Power Station	5		
3					
4					
5					

LV AC & DC TRENCH



MV AC TRENCH



LV AC & DC TRENCH



MV AC TRENCH



MV AC TRENCH - ROAD CROSSING



Legend

- MV cable 33kV
- Data network
- DC + cable 1,5 kV
- DC - cable 1,5 kV
- AC auxiliary system 0,4 kV
- CCTV and acceess control system
- Grounding&lighting system

Master Plan
BESS Glodeni
M 1:500



Lazar Laura
Digitally signed by Lazar Laura
Date: 2025.10.01 12:32:36 +03'00'

Cable Plan
BESS Glodeni
M 1:500

420×891

Save - 17.09.2025 12:59:21

Print - Bandin Vitalii 17.09.2025 13:01:01